

Qualification certificate

This product through overall and strict testing, product function and technical index of security and reliability are completely according with «safe standard for elevator manufacture and installation»

(GB7588-2003; EN81-1: 1998)



 NINGBO SHENLING LIFT ACCESSORIES CO., LTD.

ADJUSTMENT CERTIFICATE

NAME	SPEED GOVERNOR	TYPE	XSQ115-02	
PCNO	DCA20602C55	NO	14106478	
TYPE TEST CERTIFICATION NO.				
RATED SPEED (m/s)		1.00		
SWITCH SPEED (m/s)		DOWN 1.15-1.25	UP 1.15-1.25	
OVERSPEED UPWARD (m/s)		DOWN \	UP \	
TRIPPING SPEED (m/s)		DOWN 1.25-1.37	UP \	
ROPE TENSION (N)		1000-2000		
TEST RECORD				
SWITCH SPEED (m/s)	DOWN	UP	DOWN	UP
	1.216	1.226	\	\
	OVERSPEED UPWARD (m/s)	TRIPPING SPEED (m/s)		
1.200	1.210	\	\	1.313
1.198	1.208	\	\	1.290
ROPE TENSION (N)		1342		1.300
CONCLUSION			PASSED	

ADJUSTMENT DATE: QC. B INSPECTION DATE: **QC03**
 2014.09.06